



January 10, 2011

ARJO INC
GARY LOFGREN
50 N GARY AVE SUITE A
ROSELLE IL 60172

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: ARJO INC
Product Name: RHAPSODY and PRIMO SYSTEM 2000
Model Number(s): APxxxx1-US and ARxxxx1-US
The "xxxx" designates type of panel (P200, P220 or P300), length of tub shell, and hydrosound or hydromassage.
Product File No: 20110012

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2016.

This approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product as having an equivalent form of backflow protection built into the internal water supply. The product meets the intent of the code by providing a method that ensures the vacuum breakers will not be subjected to backpressure due the height of the shower or disinfectant hose.

This approval supersedes the approval issued on January 23, 2006 under product file number 20060007.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060007.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov